

# Certificate

## Passive House suitable component

For cool, temperate climates, valid until 31 December 2012

Category: **Heat recovery unit**  
Manufacturer: **Zehnder Group Nederland B.V.**  
**8028 PM Zwolle, NETHERLANDS**  
Product name: **ComfoAir 350**

**This certificate was awarded based on the following criteria:**

Thermal comfort	$\Theta_{\text{supply air}} \geq 16.5 \text{ }^\circ\text{C}$ at $\theta_{\text{outdoor air}} = -10 \text{ }^\circ\text{C}$
Effective heat recovery rate	$\eta_{\text{HR,eff}} \geq 75\%$
Electric power consumption	$P_{\text{el}} \leq 0.45 \text{ Wh/m}^3$
Airtightness	Interior and exterior air leakage rates less than 3% of nominal air flow rate
Balancing and adjustability	Air flow balancing possible:    yes Automated air flow balancing:   no
Sound insulation	Sound pressure level $L_p \leq 35 \text{ dB(A)}$ based on a 4 m <sup>2</sup> equivalent absorption area not met Here $L_p = 54.1 \text{ dB(A)}$ Unit must be installed in a separate building services room.
Indoor air quality	Outdoor air filter F7 Extract air filter G4
Frostprotection	Frost protection for the heat exchanger with continuous fresh air supply down to $\Theta_{\text{Outdoor air}} = -15 \text{ }^\circ\text{C}$

Further information can be found in the appendix of this certificate.

[www.passivehouse.com](http://www.passivehouse.com)

Passive House Institute  
Dr. Wolfgang Feist  
64283 Darmstadt  
GERMANY



**Certified for air flow rates of**

**71 – 293 m<sup>3</sup>/h**

$\eta_{\text{HR,eff}}$

**84%**

**Electric power consumption**

**0.29 Wh/m<sup>3</sup>**



**Passive House  
suitable  
component**  
Dr. Wolfgang Feist